

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

## Powered Smoke and heat control systems –Part 3: Specification for powered smoke and heat control ventilators (Fans)

for use as part of a powered smoke and heat control ventilation system in construction works.

**Product name: SEF 250, SEF 315, SEF 400 and SEF 450**

Resistance to fire: F<sub>400</sub> (120)

Motor insulation: Class F

Temperature rise at ambient: Class B

The powered smoke and heat exhaust ventilator are thermally uninsulated.

placed on the market under the name or trademark of

**EXHAUSTO A/S**

Odensevej 76

DK-5550 Langeskov, Denmark

and produced in the manufacturing plant

same as above

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard

**EN 12101-3:2015**

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

**constancy of performance of the construction product.**

This certificate was first issued on 2006-06-26 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Issued by notified body 0402

The validity of this certificate can be verified on our website.

Johan Åkesson  
Product Certification Manager

Martin Tillander  
Project Manager

Certificate 0402-CPR-453701 | issue 5 | 2018-09-04

RISE Research Institutes of Sweden AB | Certification  
Box 857, SE-501 15 Borås, Sweden  
Phone: +46 10-516 50 00  
certifiering@ri.se | www.ri.se

2017-07-06



8P04513

